GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/2023/ School/ 4477

Dated: 27/06/2023

FIRE SAFETY CERTIFICATE

Certified that Jain Happy School located at Sec.-II, DIZ Area, Gole Market, New Delhi comprises of Block -A, Ground + 02 upper floor & Block -B, Basement + Ground + 02 upper floor, was granted FSC by this department vide letter No. F6/DFS/MS/2020/School/391 dated 01/10/20. Now, the premises was re-inspected by the officer concerned of this department on 20/06/23 in the presence of Mr. Atul Jain and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from 27 06 2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on27.1.0.6/2023 at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.

2. The Principal, Jain Happy School at Sec.-II, DIZ Area, Gole Market, New Delhi.

Condition for the validity of Fire Safety Certificate

- All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
- 5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
- 9. Any flammable material for interior decoration shall strictly prohibited.
- 10. Basement shall strictly be used as per concerned BBL.

JAIN HAPPY SCHOOL

(Senior Secondary)

Sector-II, DIZ Area

Gole Market, New Delhi-110001

For JAIN HAPPY SCHOOL (RECOGNIZED)

(A Minority Educational Institution)

CBSE Affiliation No. 2730385, School No. 85016,

DOE School No. 2026123

Chairman / Manager

Shalon

Principa